

<b>TECHNICAL SHEET</b>
<b>PORC RF CMTO CONCRETO BCO 60X60 EXT 1.44</b>

EVALUATED FEATURE	TEST METHOD	NORM ANSI A137.1 REQUIREMENTS (Table 10)	RESULTS	CONCLUSION
<b>DIMENSIONS</b>				
* Nominal Size, mm Nominal Size: 600.0 mm Manufacturing Size: 600.0 mm	ASTM C499	- 3.00% / 2.00%	(%) (mm) 0.00 0.00	Comply
* Caliber Range Manufacturing Size: 600.0 mm Average Size: 600.1 mm	ASTM C499	± 0.25%; ± 0.80mm	0.02 0.10	Comply
* Warpage Edge,%	ASTM C485	± 0.40%; ± 1.30mm	0.14 0.00 0.82 0.00	Comply
* Warpage Diagonal, %	ASTM C485	± 0.40%; ± 1.80mm	0.15 0.00 1.28 0.00	Comply
* Wedging, %	ASTM C502	± 0.25%; ± 0.80mm	0.04 -0.01 0.34 -0.10	Comply
* Thickness, mm Manufacturing: 9.5 mm Average result: 9.6 mm	ASTM C499	Max. 1.02 mm	1.05 0.10	Comply
<b>PHYSICAL PROPERTIES</b>				
* Visible Abrasion Resistance	ASTM C1027	As reported	PEI IV	-
* Water Absorption, %	ASTM C373	Impervious Porcelain (P1) wa ≤ 0.5%	0.30	Comply
* Craze Resistance	ASTM C424	Pass	Approved	Comply
* Breaking Strength, lbf	ASTM C648	Average ≥ 275 Individual ≥ 250	470 452	Comply Comply
* Dynamic coefficient of friction - DCOF Wet	ANSI A137.1 Section 9.6	≥ 0.42	0.49	Comply
<b>CHEMICAL PROPERTIES</b>				
* Chemical Resistance	ASTM C650	As reported	Resistant	Comply
* Stain Resistance	ASTM C1378	As reported	Resistant	Comply
<p>Requirements verified as indicated in AMERICAN STANDARD, ANSI A137.1.            AMERICAN NATIONAL STANDARD SPECIFICATIONS FOR CERAMIC TILE / Table 10: Porcelain Tile            The weight, the tone and the dimensions are subject to some of the typical unavoidable variations of the processes of ceramic cooking.</p>				
<b>DATE OF ISSUE</b>			Wednesday, July 21, 2021	
<b>Prepared by: Quality Supervisor</b>			<b>Reviewed by: Manager Quality Assurance</b>	
César Prado R.			Marlene Chauca R.	